

ADDENDUM 1
Repair Exterior Damages
5 Units at Central Scattered Sites
Invitation for Bids
No. IFB# 22-0711-1

Housing Authority of Kansas City
3822 Summit Street
Kansas City, MO 64111

NOTICE TO ALL RESPONDENTS

The following addendum to the Invitation for Bid 22-0711-1 comprises this addendum and is hereby made part of the IFB.

Delete the following from Scope of Work:

3311 E. 38th Street

1. Wood Hand & Guard Rail Next to the street. Item 1-6 (*replaced by another party*)

Add the following to the Scope of Work:

7813 E. 48th Street (*Exit Door Handrail*):

1. Cut, replace (Weld) 3'-4' Long rusted one handrail post and it shoe plate at bottom. Secure the post with new ancho bolts and nuts
2. Remove damaged 5'-00" long fence line including post and other chain link fence members. See the fence line by left side of entry gate.

2820 E. 12th Street:

1. Cut-out & replace small area of rotted siding at rear (*See east side of exit door at bottom*).
2. Remove lower 1'x3" trims along the perimeter of siding walls.
3. Furnish and install 1'x8" band or trim to replace the rtrims removed along the perimeter.

9932 E 38th Street:

1. Another party replaced both rotted siding & insulation at front left side wall.
2. Cut & replace the rotted fascia board at edge where it touched wall.
3. Use new flashing between wall & gutter edge to prevent water penetrating inside wall.
4. It is not necessary to replace the gutter as originally called for but, the gutter can be removed and re-installed to enable seal gutter edge that leaks water.

This written response is being submitted to the Housing Authority of Kansas City, Missouri in conjunction with the IFB 22-0711-1 dated July 29,2022.

I hereby represent that I am a duly authorized agent for the company identified below, AND THAT I HAVE RECEIVED THE ADDENDUM #1.

Company: _____

Authorized Signatory: _____

Printed Name

Title: _____

Signature: _____

Date: _____

NOTE: THIS COVER PAGE MUST BE ATTACHED TO THE WRITTEN BID SUBMITTED