

**Fire Rehabilitation  
1020 Garfield Ave  
IFB 24-0613  
ADDENDUM #01**

Housing Authority of Kansas City  
3822 Summit Street  
Kansas City, MO 64111  
**Issue Date:** June 28, 2024

**NOTICE TO ALL RESPONDENTS**

This Addendum is hereby made a part of the Invitation for Bid to the same extent as if it was originally included therein and is intended to modify and/or interpret the proposal documents by additions, deletions, clarifications, or corrections. The Contractor shall acknowledge in the proposal the receipt of this Addendum.

**General Information**

Addendum #1 is in response to inquiries received that have been submitted by vendors

**Questions & Answers**

- 1.Q. Scope states that entry door frames are to remain, but entry slabs are not mentioned. Are they to remain or be replaced?  
A. **Unless they are damaged and need repaired or replaced, they will remain**
- 2.Q. Exterior side of window frames are beat up, is this reason to replace them?  
A. **We will leave the existing frames if possible and will caulk any screw holes, note: windows must operate as intended, if they do not, they will need to be completely replaced.**
- 3.Q. Front and Back exterior walls in the unit are Block walls. Are these walls just to be cleaned, primed and painted.  
A.**Yes, the walls should be cleaned, primed and painted.**
- 4.Q. Should vinyl planks be floating or glued down?  
A. **Glue down Vinyl plank flooring.**

**Addendum #1  
Fire Rehabilitation  
1020 Garfield Ave  
IFB 24-0613**

**I hereby represent that I am a duly authorized agent for the company identified below, AND THAT I HAVE RECEIVED ADDENDUM #1.**

**Company:** \_\_\_\_\_

**Authorized Signatory:** \_\_\_\_\_  
**Printed Name**

**Title:** \_\_\_\_\_

**Signature:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**NOTE: THIS COVER PAGE MUST BE ATTACHED TO THE WRITTEN BID SUBMITTED**